

MIAMI-DADE FIRE RESCUE DEPARTMENT - INSPECTION REPORT



FIRE PREVENTION DIVISION
9300 NW 41 STREET, DORAL, FLORIDA 33178
PHONE 786.331.4800 FAX 786.331.4801



PERMIT # 00121-00173

Business Address: (District 35)
 DCPS SUNSET PARK ELEMENTARY SCHOOL
 10235- SW 84 ST
 MIAMI, FL 33173

Billing Address:
 DADE COUNTY PUBLIC SCHOOLS - DCPS
 1450 NE 2 AVE ROOM 602
 MIAMI, FL 33132

RESULT: Referred to State

Resulted Date: 9/25/17

Permit Type: Education / Public Licensed Educ. Facility.

Inspection Month: September

Inspector:
 VICKY MANJARRES
 (786) 336-6820
 vickym@miamidade.gov

NOTICE OF VIOLATION AND ORDER TO CORRECT

The hazards noted herein are in violation of the Florida Fire Prevention Code and/or Miami-Dade County Code and are deemed to be threats to life safety and/or property. You are hereby ordered to comply with the corrective measures prescribed. Nothing in this report supersedes any previously written, still existing violations for this occupancy.

APPEALS

Any person who believes they were incorrectly issued a notice of violation or that the violation cited is not applicable to their occupancy classification or believes aggrieved by any action or decision of this code may appeal to the Miami- Dade County Fire Prevention and Safety Appeals Board by filing a written notice **within 30 days** of receiving the Notice of Violation and Order to Correct. The appeal request must be submitted in writing to the Secretary of the Board. Information on filing an appeal can be obtained on the web at: <http://www.miamidade.gov/fire/request-appeal.asp>. Filing of a written notice of appeal shall not stay the effect of any such action or decision which is the subject to the appeal. Section 14-36, Code of Miami-Dade County

Please Note: A Life Safety Permit required by Section 14-39, Code of Miami-Dade County, to operate the above named occupancy will be issued upon correction of all outstanding violations and payment of fees assessed. **Failure to obtain the required Life Safety Permit will result in enforcement actions including fines, citations, liens and/or orders to cease and desist operation.**

Viol.	Date Created	Comply by Date	Violation, Correction & Comments
1	9/2/14	7/14/12	Failure to comply with below violations will result in issuance of a citation
			<p>Violation: Code of Miami-Dade County. (4) Runner Service and Service Contracts. All fire alarm systems shall be required to have in effect at all times a service contract with a licensed fire alarm service contractor, a listed fire alarm service-local company or a listed central station to provide all maintenance, service and testing as required by this Code..</p> <p>Correction: Provide and maintain in effect at all times a service contract with a licensed fire alarm service contractor, a listed fire alarm service-local company or a listed central station to provide all maintenance, service and testing as required by this Code. Provide copy of contract for Fire Department review..</p> <p>Comments: DCPS #499 PROVIDE RUNNER SERVICE CONTRACT.</p>

CUSTOMER SIGNATURE

Title: Agency
 Name:

Please Note: A life safety permit will be issued upon compliance of outstanding violations and payment of fees assessed. One (1) re-inspection will be performed at no additional cost. All subsequent re-inspections will be billed at one-half the original permit fee amount.



We would like feedback on your experience with your Life Safety Inspection. Please take a minute to complete our survey at:
http://bit.ly/mdfr_2tcSXHm